

**PROTECT YOUR
DIESEL/ADBLUE® TANK**

Service & Maintenance Protection

-  **Electronic Check and Re-calibration**
-  **9 Point Visual Inspection**
-  **3 Point Nozzle Check**
-  **Replace Water Captor**
(for diesel only)
-  **Fluid Test**

Diesel and Adblue® tanks should be serviced every 6 months or every 50,000 litres dispensed, depending which occurs first.

Regular maintenance reduces running costs, eliminates downtime and increases safety in the workplace.

We conduct operational and functional checks. Servicing and replacing of necessary parts

Contact Polymaster to schedule a service

1300 062 064 | sales@polymaster.com.au | industrial.polymaster.com.au